



Number	18GR0267/02	Replaces	18GR0267/01
Issue Date	17-10-2023	Contract Number	E7701
Due Date	17-10-2033	Module	B (Type testing)
Report Number	124682	Scope	(EU) 2016/426 (9 March 2016)
P/N	0063BU1682	Page	1 of 1

## EU TYPE EXAMINATION CERTIFICATE (GAR)

Kiwa hereby declares that the Pressure sensing device, model(s):

XNS2-XXXX-XX

Manufacturer UniControl Inc.  
1111 Brookpark Road  
Cleveland Ohio  
USA

meets the essential requirements as described in the Regulation (EU) 2016/426 relating to appliances burning gaseous fuels.  
Reference standard: EN 1854:2023

This certificate is only valid in combination with the appendix to this certificate, where specific information and/or conditions are given.

Ron Scheepers  
Managing director

Kiwa Nederland B.V.  
Wilmersdorf 50  
P.O. Box 137  
7300 AC APELDOORN  
The Netherlands

<https://www.kiwaenergy.com>





Number	18GR0267/02	Replaces	18GR0267/01
Issue Date	17-10-2023	Contract Number	E7701
Due Date	17-10-2033	Module	B (Type testing)
Report Number	124682	Scope	(EU) 2016/426 (9 March 2016)
P/N	0063BU1682	Page	1 of 1

## APPENDIX TO EU TYPE EXAMINATION CERTIFICATE (GAR)

Manufacturer:

UniControl Inc.

Product information:

Pressure sensing devices approved on EN 1824.

Type:

XNS2-XXXX-XX

X	:	No letter or letter D. D: designates optional dual switch
NS2	:	Basic model Designation
XXXX	:	Number from 0000 to 9999 specifying specific construction
XX	:	Suffix number from 00 to 99 to indicate calibration set point, labelling. etc.
Sensing medium	:	Non-combustible gases
Ambient temperature range	:	°C to 88 °C
Electrical rating	:	(R1) Fine silver contacts: SPDT, SPST 1.5 resistive (1.5 inductive) Amps @ 240 VAC, 50/60 Hz  (R2) Gold alloy contacts 0.15 Amps resistive @ 24 VAC or 24 VDC, 50/60 Hz
Mounting position	:	Vertical / Horizontal
Connection size	:	6 mm push fit connection 1/4" and 3/16" push fit connection
Working pressure (maximum)	:	34.5 mbar
Special conditions	:	None